

2012-2013

Biennial Transmission Plan

SUMMARY



NTTG Mission

To ensure efficient, effective, coordinated use and expansion of the members' transmission systems in the Western Interconnection to best meet the needs of customers and stakeholders.



Above: Crews perform live-line spacer replacement on a 500-kV transmission line between switchyards in central Montana.

On the cover: A segment of the 500-kV Mona-Oquirrh transmission line runs through Tooele County, Utah.

NORTHERN TIER TRANSMISSION GROUP

www.nttg.biz
info@nttg.biz

**NTTG Members’
Transmission Facilities**



The extensive high-voltage transmission network of the Northern Tier Transmission Group’s transmission providers reaches to all states of the U.S. Western Interconnection.

1. Introduction

This document summarizes the Northern Tier Transmission Group (NTTG) 2012-2013 Biennial Transmission Plan. It highlights the key conclusions of the plan and provides limited background on the plan purpose and process. See the complete plan at the NTTG website (www.nttg.biz) for greater detail, background and graphics.

The NTTG 2012-2013 Biennial Transmission Plan sought to determine transmission system improvements needed for reliable operation in the year 2022 within the NTTG footprint of the western United States. The plan included an economic study and a transmission study.

For the economic study, NTTG combined three requests into one study. The goal of the combined study was to identify what, if any, transmission additions were required for transporting 1,500 MW of wind generation from Montana to the California-Oregon border.

For the transmission study, NTTG created a Null Case, core cases and a Scenario Case.

First, the Null Case established the inadequacy of the existing transmission system to reliably handle forecasted 2022 NTTG system electrical load.

Second, core cases examined five hours representing times of peak load as well as high transmission import and export stress. Power-flow reliability analysis on the five core cases demonstrated the adequacy of expected transmission upgrades to reliably accommodate projected loads and resources in 2022.

Third, the Scenario Case studied the impact of a proposed wind-power generating resource and a proposed high-voltage, direct-current transmission line.

This summary will explain the three components of the transmission study, including the study conclusions, as well as the economic studies performed. But first, the overall purpose of the plan, and the process used to create it, will be highlighted.

Workers install 500-kV breaker at the Idaho Power and PacifiCorp Hemingway Transmission Station in Idaho.



2. Plan Purpose

The study plan established – given a limited number of load and resource scenarios developed through production-cost simulation – whether the expected transmission improvements provide for feasible system operation at times of transmission stress 10 years in the future. The transmission planning process advanced three goals:

1. Identify transmission needs of transmission customers
2. Identify and evaluate transmission congestion that impedes efficient operation of electricity markets.
3. Consider the impacts on congestion of potential new power plants or new transmission projects.

3. Planning Process

The NTTG biennial transmission planning process started in January 2012 and ran through December 2013.

The table below diagrams the steps involved for the transmission study and the economic study.

NTTG EIGHT-QUARTER BIENNIAL PROCESS

NTTG Biennial Planning Cycle	Gather Information	01	EVEN YEARS	01	Economic Study Requests	NTTG Economic Study Cycle
	Develop Study Plan, Assumptions	02		02	Perform Economic Studies	
	Perform Draft Plan Analysis	03		03	Report and Review	
	Perform Draft Plan Analysis	04		04		
	Prepare & Review Draft Report	05	ODD YEARS	01	Economic Study Requests	
	Process Econ. Studies, Cost Alloc.	06		02	Perform Economic Studies	
	Prepare & Review Final Report	07		03	Report and Review	
	Obtain Final Plan Approval	08		04		

4. Study Methodology

NTTG created the power-flow core cases from a chronological, security-constrained, generator-commitment-and-dispatch program. The program enabled the NTTG Technical Work Group (TWG) to identify and select specific conditions, e.g., peak load and maximum export, to perform reliability analysis of the NTTG transmission system. NTTG examined all hours of the year in which available resources and forecasted loads across the Western Interconnection caused the highest stress on the transmission system within the Northern Tier footprint.

Power-flow analysis was performed on the developed cases to determine if any voltage- or thermal-overload violations existed under two conditions: system normal (N-0 pre-disturbance analysis with all lines in service) and one transmission element out of service at a time (N-1 contingency analysis). The power-flow simulation results were then measured against North American Electric Reliability Corp. (NERC) and Western Electricity Coordinating Council (WECC) reliability criteria.

5. Economic Studies

NTTG received three economic study requests during the 2012-2013 planning process and combined these into one study. The combined study determined whether transmission additions were required to transport 1,500 MW of power from Great Falls, Mont., to Malin, Ore., and how much power may be transported from Great Falls to Malin without transmission additions.


NTTG analyzed four transmission configurations for the economic study. Each configuration built on and incorporated the following four additions in an iterative process:

1. 1,500 MW of generation resource added to Great Falls and a 1,500-MW load in Malin

2. 500-kV line from Great Falls to Townsend to Midpoint with a new substation at Townsend
3. 500-kV line from Hemingway to Captain Jack
4. Second 500-kV line from Midpoint to Hemingway

The economic study demonstrated that 1,500 MW of power may be transferred from Great Falls to Malin, with the addition of a 500-kV line from Great Falls to Townsend to Midpoint and series capacitor upgrades at Burns, Malin and Midpoint. Additionally, only 400 MW may be transferred if only the 500-kV line from Great Falls to Townsend to Midpoint is added.

FIGURE 1
Tie-line flows for
Economic Study
Maximum Export Case 4



6. Null Case

The Null Case sought to discover whether the near-term transmission system could meet the demands of the NTTG footprint year 2022 forecast load. The Null Case was derived from the July 21, 2022 @ 16:00 hours case, modified to reflect the near-term transmission system by removing 23 of the 30 Common Case Transmission Assumptions (CCTA) projects.

Power-flow analysis was performed on the Null Case to determine if any voltage or thermal overload violations existed during system normal (N-0 pre-disturbance analysis with all lines in service) and

one transmission element out of service at a time (N-1 contingency analysis) as described in Chapter 2.

The Null Case demonstrated that the near-term transmission system is inadequate to meet forecasted 2022 load and resource requirements. Additional transmission would be required to reliably meet future needs.




FIGURE 2

Null Case Area Tie-line

Committee (TEPPC) 2022 production-cost model (PC1). From this model, five core cases were generated based on NTTG transmission providers' coincident:

- 1) peak summer load, 2) peak winter load,
- 3) maximum export and 4) maximum import/minimum export; and, additionally,
- 5) high California-Oregon Intertie (COI) plus Pacific DC Intertie (PDCI) southbound flow coincident with low NTTG export.

LEGEND

+MW = Flow in direction of arrow
 -MW = Flow opposite direction of arrow

GEN. MW
 AREA A
 LOAD MW

MW FLOW

GEN. MW
 AREA B
 LOAD MW

The map displays the following power plants and their capacities (MW):

- B.C. HYDRO: 12129 MW
- FORTISBC: 255 MW
- ALBERTA: 13752 MW
- MONTANA: 3030 MW
- NORTHWEST: 25618 MW
- IDAHO: 4173 MW
- SIERRA: 1840 MW
- PG AND E: 20683 MW
- NEVADA: 4686 MW
- SO CALIF: 16761 MW
- LADWP: 5727 MW
- SAN DIEGO: 3775 MW
- IMPERIAL CA: 1814 MW
- MEXICO-CFE: 2644 MW
- ARIZONA: 24059 MW
- ARIZONA: 20641 MW
- EL PASO: 850 MW
- NEW MEXICO: 3372 MW
- PS COLORADO: 6087 MW
- WAPA R.M.: 6701 MW
- WAPA R.M.: 5692 MW
- PACE: 7523 MW

The map also shows various transmission lines with power flow values (MW) such as 3104 MW, 502 MW, -733 MW, 24 MW, 483 MW, -2238 MW, 0 MW, 203 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW, 850 MW, 3372 MW, 6087 MW, 6701 MW, 5692 MW, 7523 MW, 1838 MW, 187 MW, 203 MW, 470 MW, 1838 MW, 187 MW, 109 MW, -269 MW, -162 MW, 1093 MW, -31 MW, -51 MW, -722 MW, 155 MW, 339 MW, -67 MW, 262 MW, 407 MW, 104 MW, -64 MW, 1 MW, -3522 MW, 1234 MW, 203 MW, 483 MW, 502 MW, 12129 MW, 255 MW, 13752 MW, 3030 MW, 25618 MW, 4173 MW, 1840 MW, 20683 MW, 4686 MW, 16761 MW, 5727 MW, 3775 MW, 1814 MW, 2644 MW, 24059 MW, 20641 MW,




FIGURE 4

Tie-line Flows for Winter
Peak-Load Core Case
– Jan. 5 08:00






FIGURE 5

Tie-line Flows for Maximum
Export Core Case
– Nov. 6 10:00



The five core cases demonstrated that the expected transmission projects, represented in the TEPPC PC1 model, provide adequate transmission capacity to accommodate forecasted 2022 loads

and resources. No additional transmission facilities are needed in this timeframe based on the analysis of the five stressed conditions represented in the core cases.

FIGURE 8


Foundational Projects – 2022

2022 COMMON CASE TRANSMISSION ASSUMPTIONS (CCTA)

The purpose of the CCTA is to provide a basic set of transmission facilities that TEPPC can use as a starting point for their own studies. The CCTA is a list of facilities that have a high probability of being in service by 2022.

- ① Boardman - Hemingway (B2H)
- ② Cascade Crossing
- ③ Central Ferry - Lower Monumental (Little Goose Area Reinforcement)
- ④ Delaney - Palo Verde Line
- ⑤ Delaney - Sun Valley Line
- ⑥ Devers - Colorado River (DCR) Project
- ⑦ Gateway Central Project: Mona to Oquirrh (Segment C)
- ⑧ Gateway Central Project: Sigurd - Red Butte
- ⑨ Gateway South Project: Segment 2 (Aeolus - Mona)
- ⑩ Gateway West Project: Segment 1A (Windstar to Jim Bridger)
- ⑪ Gateway West Project: Segment 1B (Bridger - Populus single circuit)
- ⑫ Gateway West Project: Segment 1C (Populus - Midpoint)
- ⑬ Gateway West Project: Segment E (Midpoint - Hemingway)
- ⑭ Hassayampa - North Gila #2 Line
- ⑮ I-5 Corridor Reinforcement Project (Castle Rock - Troutdale)
- ⑯ Interior to Lower Mainland Transmission (ILM) Project
- ⑰ Montana Alberta Tie Project (MATL)
- ⑱ Morgan - Sun Valley Line
- ⑲ Midway - Waterton
- ⑳ Path 8 Upgrade/Colstrip Transmission Upgrade (western portion only)
- ㉑ Pawnee - Smoky Hill
- ㉒ Pinal Central - Tortolita
- ㉓ Pinal West - Pinal Central - Browning (SEV)
- ㉔ San Luis Valley - Calumet - Comanche
- ㉕ Sunrise Powerlink
- ㉖ SWIP South
- ㉗ Tehachapi Renewable Transmission Project
- ㉘ Walla Walla to McNary (Energy Gateway Segment A)
- ㉙ West of McNary Reinforcement Project Group 1 (McNary - John Day)
- ㉚ West of McNary Reinforcement Project Group 2 (Big Eddy - Knight)

Blue Text - Indicates Under Construction




SUBREGIONAL COORDINATION GROUP (SCG)

CAISO - California Independent System Operator
CTPG - California Transmission Planning Group
CG - Columbia Grid
CCPG - Colorado Coordinated Planning Group
NTTG - Northern Tier Transmission Group

SIERRA - Sierra Subregional Planning Group
SWAT - Southwest Area Transmission
AESO - Alberta Electric System Operator
BCCPG - BC Coordinated Planning Group

both poles of the new bipole DC line if transferring 3,000 MW. Even tripping one-half of the wind generation in Wyoming, as recommended by TransWest Express, was insufficient to achieve acceptable results within the NTTG footprint. Study results also showed that if the TransWest Express DC line flow were reduced to 2,650 MW (receiving end), the loss of the DC bipole would be less severe, with few or no violations, depending on whether remedial action were employed.

Maximum Export TransWest
Express Reduced Scenario

9. The Northern Tier Transmission Group


The Northern Tier Transmission Group was formed voluntarily in 2007 to promote effective planning and use of the multi-state electric transmission system within the Northern Tier footprint. NTTG fulfills FERC Order 890 requiring local transmission providers to participate

in regional and subregional planning. Northern Tier provides a forum where all interested stakeholders, including transmission providers, customers and state regulators, can participate in planning, coordinating and implementing a robust transmission system.

An Erickson S-64 air crane clutches the bridge section of a 500-kV tower for the Mona-to-Oquirrh segment of PacifiCorp's Energy Gateway Transmission Expansion project.



STRUCTURE OF THE NORTHERN TIER TRANSMISSION GROUP



NTTG focuses its efforts on the evaluation of transmission projects that move power across the subregional bulk electric transmission system, serving load in its footprint and delivering electricity to external markets. The transmission providers belonging to Northern Tier serve over 4 million retail customers with more than 29,000 miles of high-voltage transmission lines. These members provide service across much of Utah, Wyoming,

Montana, Idaho and Oregon, and parts of Washington and California.

NTTG works with other entities within its footprint, the WECC Planning Coordination Committee for reliability planning, the WECC TEPPC for economic planning, and neighboring subregional planning entities.

Northern Tier Members

The Northern Tier Transmission Group's organizational structure has multiple levels, as shown above. Overall planning direction is provided by the Steering Committee, whose membership at publication was as follows:

Deseret Power Electric Cooperative
Idaho Power Company
Idaho Public Utilities Commission
Montana Consumer Counsel
Montana Public Service Commission
NorthWestern Energy
Oregon Public Utility Commission
PacifiCorp
Portland General Electric
Utah Associated Municipal Power Systems
Utah Office of Consumer Services
Utah Public Service Commission
Wyoming Office of Consumer Advocate
Wyoming Public Service Commission

Below: Workers install the mid-section of a 500-kV tower for PacifiCorp's Energy Gateway Transmission Expansion project in Utah.

On the back cover: NorthWestern Energy's 500-Kv transmission line skirts the northern edge of the Crazy Mountains in Montana.



