



NTTG - ATC Narratives for Changes in TTC

Changes on December 2008 from June 2008 ATC submittal

**Explanations of Monthly or Yearly ATC changes caused by a 10% or greater change in path TTC:
Changes as compared to the Northern Tier Transmission Group June 2008 ATC Update**

Transmission Provider	Posted Path	Explanation
PacifiCorp	BORA-PATHC	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	BRDY-PATHC	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	DeerCreek-PACE	This is an internal path posted to deliver energy under a customers contract obligations and was modified according to planning and customer contract rights.
PacifiCorp	PACE-REDBL	PACE-REDB was split into PACE-REDBL and REDBL-REDB
PacifiCorp	REDBL-REDB	PACE-REDB was split into PACE-REDBL and REDBL-REDB
PacifiCorp	PATHC BORA - HLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BORA - LLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BRDY - HLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BRDY - LLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	WEED-CRAG	The posting was modified to accommodate upgrades completed on a parallel path for load service.
PacifiCorp	PACE-PATHC - HLH	TTC was reduced to specific numbers by month (capacity must be adjusted hourly for load and temperature) until December 31, 2008 at which time the previous TTC will be re-instated
PacifiCorp	PACE-PATHC - LLH	TTC was reduced to specific numbers by month (capacity must be adjusted hourly for load and temperature) until December 31, 2008 at which time the previous TTC will be re-instated
PacifiCorp	REDBL-PACE	PACE-REDB was split into PACE-REDBL and REDBL-REDB

As of December 2008
Approved for Posting 01-23-09

PacifiCorp	BORA-PATHC	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	BRDY-PATHC	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PACE-REDBL	PACE-REDB was split into PACE-REDBL and REDBL-REDB
PacifiCorp	REDBL-REDB	PACE-REDB was split into PACE-REDBL and REDBL-REDB
PacifiCorp	PATHC BORA - HLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BORA - LLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BRDY - HLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
PacifiCorp	PATHC BRDY - LLH	BOBR-PATHC was split into BORA-PATHC and BRDY-PATHC
NorthWestern Energy	WS/NWMT/BPAT-NWMT/BPAT.NWMT-NWMT.SYSTEM/	The TTC was re-studied and resulted in new TTC values.
NorthWestern Energy	WS/NWMT/NWMT-BPAT/NWMT.SYSTEM-BPAT.NWMT/	TTC of 508 is the normal TTC value. TTC of 581 was applied during an outage condition thus increasing the TTC value for a short time.
Idaho Power	W/IPCO/PCWY-IPCO/JBSN-IPCO	Previously reflected total path TTC, now only reflecting IPCO share of TTC. No actual change in Path TTC, just reflecting contractual rights.
Idaho Power	W/IPCO/IPCO-PACE/IPCO-HTSP	Reflects change in TTC due to OMS implementation by NWMT for AMPS line.
Idaho Power	W/IPCO/PACE-PACE/BRDY-MLCK	Reflects change in TTC due to OMS implementation by NWMT for AMPS line.
Idaho Power	W/IPCO/PCWY-IPCO/JBSN-IPCO	Previously reflected total path TTC, now only reflecting IPCO share of TTC. No actual change in Path TTC, just reflecting contractual rights.