



NTTG - ATC Narratives for Changes in TTC

Changes as of December 2010 from June 2010 ATC submittal

**Explanations of Monthly or Yearly ATC changes caused by a 10% or greater change in path TTC:
Changes as compared to the Northern Tier Transmission Group December 2010 ATC Update**

| Transmission Provider | Posted Path | Explanation |
|-----------------------|---|--|
| Northwestern Energy | WS/NWMT/NWMT-AVA/NWMT.SYSTEM-AVAT.NWMT/ | Change in reporting philosophy. 382 was always the TTC listed on the OASIS. 85MW's was previously held out of the reported TTC in this document because it is held by other owners. The current winter season shows the full 382, with the 85 reflected in the Total Firm Obligations, as it is on the OASIS. The resulting ATC remains unchanged. This is reflective of our OASIS system where the TTC has remained unchanged at 382. |
| Northwestern Energy | WS/NWMT/NWMT-GWA/GTFALLSNWMT-GLWND1/ | TTC changed due to most recent Path Study |
| Northwestern Energy | WS/NWMT/NWMT-NWMT/GLWND1-GLWND2/ | TTC changed due to most recent Path Study |
| Northwestern Energy | WS/NWMT/WAPA-NWMT/GREATFALLS-NWMT.SYSTEM/ | TTC changed due to most recent Path Study |
| PacifiCorp | HERMISTONGEN-HERMISTONGEN | New scheduling path |
| PacifiCorp | M500-HMWY | New scheduling path with addition of Hemingway |
| PacifiCorp | HMWY-SUMMERLAKNT | New scheduling path with addition of Hemingway |
| PacifiCorp | ENPR-HURR | New scheduling path with addition of Hurricane |
| PacifiCorp | HURR-WALLAWALLA | New scheduling path with addition of Hurricane |



| Transmission Provider | Posted Path | Explanation |
|-----------------------|---------------------------|--|
| PacifiCorp | COOSPAC-COOSPAC | New scheduling path |
| PacifiCorp | SALEMPAC-SALEMPAC | New scheduling path |
| PacifiCorp | PENDLETONPAC-PENDLETONPAC | New scheduling path |
| PacifiCorp | SANTIAMPAC-SANTIAMPAC | New scheduling path |
| PacifiCorp | ALBANY12PAC-ALBANY12PAC | New scheduling path |
| PacifiCorp | YAKIMAPAC-YAKIMAPAC | New scheduling path |
| PacifiCorp | RESTON230-RESTON230 | New scheduling path |
| PacifiCorp | YAMSAY230-YAMSAY230 | New scheduling path |
| PacifiCorp | SUMMERLAKNT-HMWY | New scheduling path with addition of Hemingway |
| PacifiCorp | HMWY-M500 | New scheduling path with addition of Hemingway |
| PacifiCorp | WALLAWALLA-HURR | New scheduling path with addition of Hurricane |
| PacifiCorp | HURR-ENPR | New scheduling path with addition of Hurricane |
| PacifiCorp | WEED-CRAG | TTC increased from 80 MW to 100 MW, transmission configuration change |
| PacifiCorp | NWMT-MLCK | New scheduling path with the change of Hot Springs to NWMT |
| PacifiCorp | MLCK-NWMT | New scheduling path with the change of Hot Springs to NWMT |
| PacifiCorp | KPRT-GSHN | TTC increased from 500 MW to 750 MW, transmission configuration change |



| Transmission Provider | Posted Path | Explanation |
|-----------------------|----------------------------|--|
| PacifiCorp | GSHN-PATHC | TTC increased from 148 MW to 348 MW, transmission configuration change |
| PacifiCorp | PATHC-NUT - HLH | TTC increased from 980 MW to 1600 MW, system element addition |
| PacifiCorp | PATHC-NUT - LLH | TTC increased from 980 MW to 1600 MW, system element addition |
| PacifiCorp | NUT-PATHC - HLH | TTC increased from 810 MW to 1250 MW, system element addition |
| PacifiCorp | NUT-PATHC - LLH | TTC increased from 810 MW to 1250 MW, system element addition |
| PacifiCorp | BRDY-PATHC | TTC decreased from 550 MW to 452 MW, transmission configuration change |
| PacifiCorp | NUT-PACE | TTC increased from 700 MW to 1975 MW, system element addition |
| PacifiCorp | PATHC BRDY - HLH | TTC decreased from 550 MW to 452 MW, transmission configuration change |
| PacifiCorp | PATHC BRDY - LLH | TTC decreased from 550 MW to 452 MW, transmission configuration change |
| PacifiCorp | PACE-NUT | TTC increased from 913 MW to 2150 MW, system element addition |
| PacifiCorp | WYOCENTRAL-WYOEAST | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | WYOEAST-WYOCENTRAL Nov-Mar | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | WYOEAST-WYOCENTRAL Apr-Oct | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | WYOEAST-WYONORTH Nov-Mar | Changed scheduling path from Wyoeast-TOT4B to Wyoeast-Wyonorth |



| Transmission Provider | Posted Path | Explanation |
|-----------------------|------------------|--|
| PacifiCorp | SUMMERLAKNT-PACW | New scheduling path with addition of Summer Lake |
| PacifiCorp | PACW-SUMMERLAKNT | New scheduling path with addition of Summer Lake |
| PacifiCorp | WestValley-PACE | New scheduling path |
| PacifiCorp | PACE-WestValley | New scheduling path |
| PacifiCorp | PACE-REDBL | TTC decreased from 663 MW to 503 MW, transmission configuration change |
| PacifiCorp | JBSN-WYOCENTRAL | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | FGE-WYOCENTRAL | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | NUT-TRONA | New scheduling path following change of Monument to Trona |
| PacifiCorp | TRONA-WYOCENTRAL | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | YTP-WYONORTH | New scheduling path following removal of PACEW |
| PacifiCorp | WYOCENTRAL-JBSN | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | WYOCENTRAL-FGE | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | WYOCENTRAL-TRONA | New scheduling path following change of Wyoswest to Wyocentral |
| PacifiCorp | TRONA-NUT | New scheduling path following change of Monument to Trona |
| PacifiCorp | WYONORTH-YTP | New scheduling path following removal of PACEW |
| PacifiCorp | WYOEAST-WYODAK | New scheduling path following removal of PACEW |
| PacifiCorp | WYOEAST-DJ | New scheduling path following removal of PACEW |