



NTTG - ATC Narratives for Changes in TTC

Changes as of December 2011 from June 2011 ATC submittal

**Explanations of Monthly or Yearly ATC changes caused by a 10% or greater change in path TTC:
Changes as compared to the Northern Tier Transmission Group December 2011 ATC Update**

Transmission Provider	Posted Path	Explanation
Deseret	MDGT-BOZ	The TTC on the MDGT-BOZ path changed due to the application of the NERC MOD-029 standard.
Idaho Power Company	W/IPCO/IPCO-NWMT/IPCO-JEFF	Derated to correct low line clearance until further notice.
Northwestern Energy	WS/NWMT/NWMT-NWMT/GLWND1-GLWND2/	Other - Removed 20MW of non-firm to reflect a more conservative value due to monitoring requirements for the line thermal rating.
Northwestern Energy	WS/NWMT/NWMT-NWMT/GLWND2-GLWND1/	Other - Removed 20MW of non-firm to reflect a more conservative value due to monitoring requirements for the line thermal rating.
Northwestern Energy	MT-SE	TTC is based on a nomogram with variable TTC based on system conditions. The new value reflects a more conservative import value.
PacifiCorp	HERMISTONGEN-HERMISTONGEN	New scheduling path
PacifiCorp	M500-PACW	Changed scheduling path with addition of Hemingway
PacifiCorp	M500-SUMMLAKNT	New scheduling path with addition of Summer Lake
PacifiCorp	M500-Hemingway	New scheduling path with addition of Hemingway
PacifiCorp	Hemingway-SUMMERLAKNT	New scheduling path with addition of Hemingway



Transmission Provider	Posted Path	Explanation
PacifiCorp	ENPR-WALLAWALLA	Changed scheduling path with addition of Hurricane
PacifiCorp	ENPR-HURR	New scheduling path with addition of Hurricane
PacifiCorp	HURR-WALLAWALLA	New scheduling path with addition of Hurricane
PacifiCorp	SUMMERLAKNT-M500	Changed scheduling path with addition of Hemingway
PacifiCorp	SUMMERLAKNT-HMWY	New scheduling path with addition of Hemingway
PacifiCorp	HMWY-M500	New scheduling path with addition of Hemingway
PacifiCorp	WALLAWALLA-ENPR	Changed scheduling path with addition of Hurricane
PacifiCorp	WALLAWALLA-HURR	New scheduling path with addition of Hurricane
PacifiCorp	HURR-ENPR	New scheduling path with addition of Hurricane
PacifiCorp	WEED-CRAG	Increased TTC to 100 MW to match WECC Path Catalog
PacifiCorp	BPAT.NWMT-MLCK	TTC reduced from 170 MW to 90 MW, MOD-008
PacifiCorp	AVAT.NWMT-MLCK	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	NW.MT-MLCK	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	MLCK-ANTE	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	NW.MT-BPAT.NWMT	TTC reduced from 170 MW to 45 MW, MOD-008
PacifiCorp	NW.MT-AVAT.NWMT	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	MLCK-NW.MT	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	ANTE-MLCK	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	BRDY-ANTE (Nov thru March)	TTC reduced from 250 MW to 90 MW, MOD-008
PacifiCorp	KPRT-GSHN	TTC increased from 500 MW to 750 MW, transmission configuration change



Transmission Provider	Posted Path	Explanation
PacifiCorp	GSHN-PATHC	TTC increased from 148 MW to 348 MW, transmission configuration change
PacifiCorp	PATHC-NUT - HLH	TTC increased from 980 MW to 1600 MW, system element addition
PacifiCorp	NUT-PATHC - HLH	TTC increased from 810 MW to 1250 MW, system element addition
PacifiCorp	REDB-REDBL	TTC increased from 300 MW to 580 MW, system element addition
PacifiCorp	REDBL-PACE	TTC increased from 300 MW to 580 MW, system element addition
PacifiCorp	BORA-PATHC	Changed scheduling path with addition of Populus
PacifiCorp	BORA-POP	Changed scheduling path with addition of Populus
PacifiCorp	POP-PATHC	Changed scheduling path with addition of Populus
PacifiCorp	BRDY-PATHC	TTC reduced from 550 MW to 452 MW, transmission configuration change
PacifiCorp	NUT-PACE	TTC increased from 700 MW to 1975 MW, system element addition
PacifiCorp	HUNTER-PACE	New scheduling path
PacifiCorp	HUNTER-HUNTER	New scheduling path
PacifiCorp	BOZ-ANDK	New scheduling path
PacifiCorp	REDBL-REDB	TTC increased from 300 MW to 354 MW, system element addition
PacifiCorp	PATHC BORA - HLH	Changed scheduling path with addition of Populus
PacifiCorp	PATHC BORA - LLH	Changed scheduling path with addition of Populus
PacifiCorp	PATHC-POP	Changed scheduling path with addition of Populus
PacifiCorp	POP-JBWT	Changed scheduling path with addition of Populus



Transmission Provider	Posted Path	Explanation
PacifiCorp	POP-BORA	Changed scheduling path with addition of Populus
PacifiCorp	PATHC BRDY - HLH	Changed scheduling path with addition of Populus
PacifiCorp	PATHC BRDY - LLH	Changed scheduling path with addition of Populus
PacifiCorp	PACE-NUT	TTC increased from 913 MW to 2150 MW, system element addition
PacifiCorp	JBSN-POP	Changed scheduling path with addition of Populus
PacifiCorp	POP-JBSN	Changed scheduling path with addition of Populus
PacifiCorp	Antelope-WYOEAST	New scheduling path
PacifiCorp	WYOEAST-Antelope	New scheduling path